

## **How to Check for a Water Leak**

Do not turn the valve off in the meter box!

First walk out to your meter, remove the lid and write down the current meter reading. Do not use any water in your home for three (3) to four (4) hours. After the specified amount of time has lapsed, remove the lid and write down the current reading. If the meter reading has changed the leak would be between the meter and the house. Locate your shut off valve inside your home and shut water off. If the reading has not changed open the shut off valve inside your home and repeat the same steps above to see if the leak is inside. After opening the shut off valve inside, if the meter reading changes the leak would be inside your home.

If the reading has not changed, you do not have a leak. Subtract the first reading from the last and this will inform you how much water you lost during the test.

A small leak may take longer to significantly show a difference on your meter. If you are not convinced with the 3 to 4 hour tests, choose a day when no one will be at home for 10 to 12 hours. Even the smallest drip should show up during this time. If you determine a leak is present the next step is to find the location of the leak. First, look for a wet spot on the ground between the meter and your home.

If no leaks were found, a thorough inspection of your pipes, lines, connections and valves under your home or in your basement, would be the next step.

Your hot water tank could have a hole rusted in the bottom or the drain valve may be leaking. An inspection should also be made of your toilet tanks. Water can leak out by flowing over and down the overflow pipe without the tank making any noise to alert you to the problem. The toilet does not have to be running (filling back up) for this to happen. It can continue to overflow after the toilet noise has cut off. Sometimes the rubber stopper or plunger in the bottom of the tank will not seat or close properly causing the continual overflow and loss of water. Also inspect the chain that connects the handle lever and the rubber plunger. It may become entangled also causing the same problem. The round bobber-like float may also need bending down to shut the water off earlier before it runs over the overflow pipe. Again, there may be no audible sounds that will alert you to any of these problems in your toilet tank. Frequent inspections are recommended to avoid problems.

By following these simple steps, you should be successful in finding accurate results that could save you money.

For more information contact the Town of Luray Office between 8:00 a.m. and 5:00 p.m. Monday through Friday at 540-743-5511.

\*\*\*\*\*

Water costs money.....don't waste it!

A dripping faucet or fixture can waste 3 gallons a day.....a total of 1,095 gallons a year!

Diameter of stream Water wasted in 90 days at an average of 60 psi water pressure:

- A 1/4" stream / diameter hole can waste 1,181,500 gallons of water.
- A 3/16" stream / diameter hole can waste 666,000 gallons of water.
- A 1/8" stream / diameter hole can waste 296,000 gallons of water.
- A 1/16" stream / diameter hole can waste 74,000 gallons of water.

